

**DELHI JAL BOARD: GOVT. OF NCT OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER (RWH/GWC)
ROOM NO. 209, VARUNALAYA PHASE-I
KAROL BAGH, NEW DELHI - 110005
23558264**

No./DJB/EE(RWH/GWC)/2018/ 8038

DATED: 01/11/18


To,

Manager,
New Sainik Sr. Sec. Public School,
Qutub Vihar, P.O. Goyala Dairy,
New Delhi-71


**Subject:- Regarding adequacy of rain water harvesting system at New Sainik
Sr. Sec. Public School, Qutub Vihar, P.O. Goyala Dairy, New Delhi-71.**

The above site was inspected on dated 13.11.2018 by NGT constituted team and found that two nos. RWH structure of sizes 4.5 m x 3.0 m x 3.0 m & 2.0 m x 2.0 m x 3.0 m without bore well are existing at site. The said RWH structures are sufficient to harvest the roof top area of 2530sqm. out of 8239sqm. plot area. The existing RWH structures are found adequate and functional.

You are requested to keep the existing RWH system neat & clean & maintain the same periodically.


Manager
New Sainik Public School
Qutub Vihar, Ph-I
Goyala Dairy N.D.-71


Principal
NEW SAINIK PUBLIC SCHOOL
Qutub Vihar Phase-1
New Delhi-110071


EE (RWH/GWC)
EE (GWC CELL)
DELHI JAL BOARD
VARUNALAYA PHASE-I
KAROL BAGH, N.D.-05